

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/Assembly/2025/SZ/211

Dated: 28/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Sports Blocks Indraprastha Institute of Information Technology, Okhla Industrial Estate, Phase-III, New Delhi -110020** comprised of Ground & Three Upper Floors was issued FSC by this department vide letter no. F6/DFS/MS/Assembly/SZ/2022/138 dated 31/03/2022. The premise was re-inspected by the officer concerned of this department on 19/04/2025 in the presence of Mr. Sanjay Roy, Chief Engineer (Civil) & Mr. Anurag Tyagi and found that the said building block have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Class **Group D "Assembly Building"** with effect 28/04/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on...28/04/2025... at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Dr. Deepika Bhaskar (Registrar) Sports Blocks Indraprastha Institute of Information Technology, Okhla Industrial Estate, Phase-III, New Delhi -110020
2. The Executive Engg. (Bldg.), MCD, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi 110024

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Sports Block, Indraprastha Institute of Information Technology, Okhla Industrial Estate, Phase-III, New Delhi-110020
2. Type of Occupancy : Class-D "Assembly"
3. Type of Case : Renewal [Sports Block: GF + 3 Upper floors]
4. Details of Previous NOC : F6/DFS/MS/Assembly/SZ/2022/138 dated 31/03/2022
5. Fire Safety directives letter No : Nil
6. Date of inspection : 19/04/2025
7. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
8. Name and designation of officers
From the building side : Mr. Sanjay Roy. Chief Engineer (Civil) & Anurag Tyagi
9. Year of Construction : 2018
10. Applicant's letter No. : Outdoor diary no 146 dated 03/04/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old Noc Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12m 4.5m 6m	12m 5m As per approved plan	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors 	GF to 1 st F: 2 Nos GF to Terrace: 2 Nos -NA-	Provided -NA-	MR -NA-
	<ul style="list-style-type: none"> • Basements 			
	b. Width of staircases	2m	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor • Basements 	-NA-	-NA-	-NA-
	c. Protection of exits	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required 2 Nos	Natural Ventilation Provided	MR MR
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	2m	Provided (final exit)	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door 	Required Required Required	Provided Provided Inspection panel doors are in open corridor	MR MR MR
	<ul style="list-style-type: none"> • Water Curtain • Fire Dampers 	-NA- -NA-	-NA- -NA-	-NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	24 No's ABC/ W. CO ₂ /CO ₂ ISI	Provided 8/8/8 Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Three 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	Smoke & Heat Ground Floor -NA-	Provided Provided -NA- Provided	MR MR -NA- MR

2/13

	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground & Upper Floors 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	03Nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	03Nos	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02 Nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02 Nos	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 	[Two Pump Room(PR) with similar set of Pumps]		
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2850LPM:PR-1 2850LPM:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	90m:PR-1 90m:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	Two:PR-1 Two:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	2 Nos of 180 LPM:PR-1 2 Nos of 180 LPM:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	90m:PR-1 90m:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2280LPM:PR-1 2280LPM:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	90m:PR-1 90m:PR-2	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	-NA-	450 LPM	-NA-
	<ul style="list-style-type: none"> ➤ Head of the pump 	-NA-	35m	-NA-
	<ul style="list-style-type: none"> ➤ Power Supply 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	5,00,000 Lts	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 Lts.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	Required	Natural Ventilation	MR
	<ul style="list-style-type: none"> Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	Required	Provided	MR

	<ul style="list-style-type: none"> Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Assembly/SZ/2022/138 dated 31/03/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
21/4/2024

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

[Signature]
21/4/2024

[Signature]
23/4/2024

[Signature]
24/4/24

ADO/BCP

As approved, F-7 letter is put up for your signature

[Signature]
25/4

[Signature]
25/4/24

2