



c/39

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2025/ 105

Dated: 14/02/2025

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Basai Dara Pur,
New Delhi -110015.

Sub: - Inspection report in respect of Govt. Sarvodaya Kanya Vidyalaya, Located at Basai Darapur, New Delhi -110015.

Sir,

Please refer to your letter no. No. SKV/BDP/2025/434 dated 13/01/2025 received through outdoor diary No. 11420 dated 14/01/2025 on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 04/02/2025 in the presence of Smt. Anu Gera (H.O.S) and observed that this department has already issued a letter to rectify the shortcomings vide letter No. F6/DFS/MS/School/WZ/2022/654 dated 21/10/2022 is still not complied.

In view of above Shortcomings the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,


(Atul Gang)
Director

Copy to:

1. The Director, Directorate of Education, Old Secretariat, Delhi – 110054.

o/c
13/2/2025



7
भारतीय
अग्नि महोत्सव
C-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/ 2022/ 654

Dated: 21/10/2022

To
The Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Basai Dara Pur,
New Delhi -110015.

Sub: - Inspection report in respect of Sarvodaya Kanya Vidyalaya, Located at Basai Darapur, New Delhi -110015.

Sir,


Please refer to your letter no. SKV/BDP/2022/1826 dated 23/08/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was re inspected by the officer concerned of this department on 01/09/2022 in presence of Sh. Vishnu Singh (Estate Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is comprised of Ground + Three Upper Floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, Terrace Pump, Overhead Tank etc provided. However, the following Shortcomings were observed.

1. First Aid Hose Reels & Internal Hydrant is provided but not functional.
2. Main fire pump of capacity 450 lpm is provided but not function.
3. Overhead water storage tank capacity of 10,000 ltr found empty.

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.


19/10/22