



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F.6/DFS/MS/School/2025/WZ/1204

Dated: 29/09/2025

FIRE SAFETY CERTIFICATE

Certified that the St. Angel's School, (Senior Secondary), A-Block, Sector-15, Rohini, Delhi-85, comprised of 03 Blocks, A-Block Basement + Ground + 03 upper floor & B & C Blocks, Ground + 01 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/2022/WZ/973 dated 06.09.2022. The premises was re-inspected by the officer concerned of this department on 16.09.2025 in the presence of Mr. Archit Bhardwaj and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Group B" Educational with effect from 29/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/09/2025 at New Delhi by


 26/9/2025
 (Virendra Singh)
 Chief Fire Officer
 Delhi Fire Service

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54
2. The Principal, St. Angel's School, (Senior Secondary), A-Block, Sector-15, Rohini, Delhi-85.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : St. Angefs School, (Senior Secondary), A-Block, Sector-15, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (03 Blocks, A-Blk -B+G+3 & B & C- Blk- Gr.+01)
4. Details of Previous NOC : F.6/DFS/MS/School/2022/WZ/973 dated 06.09.2022.
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 16.09.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers From the building side : Mr. Archit Bhardwaj
9. Year of Construction :
10. Applicant's letter No. : OD No.5400 dated 28.08.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	A-Blk-B+G+3=02 B-Blk- G+1=02 C-Blk-G+1=02	02nos. 02nos. 02son.	MR MR MR
	• Basements	A-Blk-B+G+3=02	02nos.	MR
	b. Width of staircases			
	• Upper Floor	1.5m	A-blk-1.5m each B-blk-1.5 & 1.2m C-blk-1.5m & 1.2m	MR MR MR
	• Basements	1.5m	1.5m each	MR
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust fan	MR
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	12nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

Am

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	Required	Provided	-NA-
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
12.	Yard Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900lpm	900lpm	MR
		40m	40m	MR
		Required	Provided	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000ltr	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	Exit Signage.	15,000ltr	25,000ltr	MR
16.	Provision of Lifts.	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

Special Fire Protection System for Protection of special Risks, if any:

-NA-

-NA-

-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/School/2022/WZ/973 dated 06.09.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW) N/A

~~1/484-N/A~~

~~22/09/25~~

~~Dy. CFO (WZ)~~

~~*[Signature]*~~
22/9

~~efo / *[Signature]*
22/9/2025
Principal Director~~

~~efo to *[Signature]*
22/09/25~~

~~efo / *[Signature]*
24/9/2025~~

~~ADO (Rohini)~~

FT letter is put up for kind perusal & sign. Plz

[Signature]
24/9/25

~~efo / *[Signature]*
26/9/2025~~

MS