



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/WZ/2025 / 14

Dated:- 25/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. Starland Desire (A Unit of Vogue Celebration LLP) located at B-21, GF, FF, SF, G.T. Karnal Road Industrial Area, Delhi-110033, comprised of Ground, Mezzanine-I, First Floor, Mezzanine-II & Second Floors only, owned/occupied by M/s. Starland Desire (A Unit of Vogue Celebration LLP), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/BNQT/2022/WZ/23 dated 26/04/2022. The said premise was re-inspected by the officer concerned of this department on 16/03/2025 in the presence of Ms. Manisha (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D-3 (Banquet Hall) with effect from 25/03/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 25/03/2025 at New Delhi by

(Atul Garg)  
Director

Tel No. 011-23414000

Copy to:-

1. The Joint Commissioner of Police, Licensing unit, 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi in r/o online application id. 2025022002161 dated 25/02/2025
2. The Dy. Commissioner, (Civil Line Zone), Municipal Corporation of Delhi, 16, Rajpura Road, New Delhi-110054.
3. The Authorized Signatory, M/s. Starland Desire (A Unit of Vogue Celebration LLP), B-21, GF, FF, SF, G.T. Karnal Road Industrial Area, Delhi-110033.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

10/21

1. Name & address of the building : M/s. Starland Desire (A Unit of Vogue Celebrators LLP), located at B-21, GF, Mezz.-I, FF, Mezz-II & SF, G.T. Karnal Road, Industrial Area, Delhi-110033
2. Type of Occupancy : Assembly Building (Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/BNQT/2022/WZ/23 dated 26/04/2022
5. Fire Safety directives Letter No. : F6/DFS/MS/2019/168 dated 02/05/2019
6. Date of inspection : 16/03/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Ms. Manisha (Manager)
9. Year of Construction : 2018
10. Applicant's Online ID. : 2025022002161 dated 25/02/2025

The banquet hall building is comprised of Ground, Mezzanine-I, First Floor, Mezzanine-II & Second Floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	18 m (approx)	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2.0 m, 1.5 m	Provided	MR
		NA	NA	NA
	• Basements	Required	Provided	MR
	c. Protection of exits	NA	NA	NA
	• Fire check door	01	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2.0 m & 1.5 m	Provided	MR
	e. Width Of Corridor			
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	15 nos.	16 nos.	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

2/22

7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	70 m	Provided	MR
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	70 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00,000 ltrs.	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;			
		NA	NA	NA
		NA	NA	NA

H/23

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measured as required under the rules, the FSC issued vide letter no. F6/DFS/MS/BNQT/2022/WZ/23 dated 26/04/2022, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly, DFA is prepared & put up for approval please.

*Amita*  
20/03/25  
Aman Kumar Lathar  
ADO (JWP)

*DO (WZ)*

*[Signature]*  
20/03/2025

*By ADO (WZ)*

*[Signature]*  
20/3/2025

*20/3/2025*

*efo/*  
*[Signature]*  
20/3/2025  
*Director*  
*[Signature]*

*As per*

Sir, F.I. letter is put-up for your signature pl.

*Director*  
*[Signature]*

*Amita*  
20/03/25  
ADO (JWP)

*Uplanded*  
26/03/25