

C-184

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/Business/2026/SZ/42

Dated: 13/02/2026

To,

Mr. Anil Pandit, Lt. Col (Security Officer),  
Ministry of Defence, Security office,  
MoD office Complex, KG Marg,  
New Delhi - 110001.

Sub: Application for grant of fire safety certificate in r/o **Steel Structure Non - Residential (GPOA), at Africa Avenue (Near Sarojini Nagar Depot), New Delhi.**

Sir,

This has a reference to letter No. 1049/Fire Audit/Security dated 24/12/2025 received through outdoor diary No. 9931 dated 07/01/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 09/01/2026 in the presence of Sh. Umendra Meena, AE/Elec. The following shortcomings are observed: -

1. Some places of the corridor found blocked with offices.
2. Sealing of electrical shaft found not provided.
3. Smoke management system in upper floors found non-functional.
4. Pumps are not in Auto Mode.
5. Pressurization in lift shaft found non-functional.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
12/2/26

(A. K. Malik)  
Dy. Chief Fire Officer, SZ  
Delhi Fire Service

o/cw