



c 52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F.6/DFS/MS/School/WZ/2025/1385

Dated: 09/12/2025

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Vidyalaya, Mansarover Garden, F-Block, New Delhi (School Id-1516003), comprised of Ground + 03 upper floors was inspected by the officer concerned of this department on 27.11.2025 in the presence of Mr. Sanjay Singh and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class 'Group B Educational' with effect from 09/12/2025 for a period of 03 (Three) years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/12/2025 at New Delhi by


(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to:

1. The Assistant Engineer (E), Edu. Sub-Divn M1-1, (N), PWD, ITI Campus, Pusa, New Delhi-110012.
2. The Principal, Govt. Sarvodaya Vidyalaya, Mansarover Garden, F-Block, New Delhi (School Id-1516003).
3. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Govt. Sarvodaya Vidyalaya, Mansarover Garden, F-Block, New Delhi (School Id-1516003)
2. Type of Occupancy	Educational
3. Type of Case	New Case (Ground + 03 upper floors)
4. Details of Previous NOC	-NA-
5. Fire Safety directives letter No	NBC Part-IV
6. Date of inspection	27.11.2025
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)
8. Name and designation of officers From the building side	Mr. Sanjay Singh
9. Year of Construction	2025
10. Applicant's letter No.	OD No.6712 dated 06.10.2025

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03nos.	03nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	3 x 1.80m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	03nos.	03nos.	MR
	e. Width of Corridor	1.5m	1.7m	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour/ Naturally ventilated	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	20	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	03nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR

Ay

	c) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	02no. Provided	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	2 x 450lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	2 x 5000ltr	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	-NA-	-NA-	-NA-
	d) Fireman's Grounding Switch	-NA-	-NA-	-NA-
	e) Lift Signage	-NA-	-NA-	-NA-

17.	Standby power supply			
18.	Refuge Area.	-NA-	-NA-	-NA-
	a) Total Area			
	b) Location	-NA-	-NA-	-NA-
19.	Fire Control Room	-NA-	-NA-	-NA-
	a) Detector System Panel			
	b) Flow Switch Panel	-NA-	-NA-	-NA-
	c) PA System Panel	-NA-	-NA-	-NA-
	d) Battery backup	-NA-	-NA-	-NA-
	e) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.
 Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

[Handwritten Signature]
 11/12/25

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Wazirpur/MN)

~~DO (W)~~ *[Signature]*
 02/12/25

~~Dy CFS~~ *[Signature]* ~~ADP~~ *[Signature]*
 02/12/25
 Principal Director

~~Dy. CFS (WZ)~~ *[Signature]*

~~Dy. CFS to Secy.~~ *[Signature]*
 02/12/25

F.T. please.

~~ADO (WZ)~~ *[Signature]*

~~ADP~~ *[Signature]*
 03/12/25

FT letter is put up for ICD perusal and signature please.

~~DOO (WZ)~~ *[Signature]* ~~ADP~~ *[Signature]*
 05/12/25
 F.P. wing

[Handwritten Signature]
 11/12/25