



c-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2026/WZ/EH/251

Dated: 25/03/2026

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name and Style of The Monarch By Royale (A Unit Of N & K Food and Flavours) located at Ground Floor, Hall No. A & B, Block -01, Garg Trade Center, Sector-11, Rohini, Delhi-1100085 in a building comprised of Basement, Ground & 03 Upper Floors owned/occupied by M/s The Monarch By Royale (A Unit Of N & K Food and Flavours) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 12/03/2026 in the presence of Mrs. Nisha Lakra (Owner) and that the building/ premise is fit for occupancy Class "**Group-D Assembly (Restaurant) at Ground floor only** with effect from25/03/2026..for period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on25/03/2026.. at New Delhi by

25/03/26
(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, to ensure the occupancy as detailed above deviation and if any. Online ID No-2026022602121 dated 26/02/2026.
2. The Monarch By Royale (A Unit Of N & K Food and Flavours) located at Ground Floor, Hall No. A & B, Block -01, Garg Trade Center, Sector-11, Rohini, Delhi-1100085.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid only for restaurant at ground floor. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
8. The owner / occupier shall submit a declaration **every year** in Form "**K**" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
9. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the MHA portal along with a copy of this Certificate, **six months** prior to its expiry".

M/12

INSPECTION REPORT

1. Name & address of the building	M/s The Monarch By Royal (A Unit Of N & K Food and Flavours) at Ground Floor, Hall No. A & B, Block -01, Garg Trade Center, Sector-11, Rohini, Delhi-1100085
2. Type of Occupancy	Group - D Assembly (Restaurant)
3. Building Comprised of	Basement, Ground + 03 Upper Floors But (The Restaurant is running at Ground floor only)
4. Type of Case	New
5. Details of Previous NOC	Nil
6. Fire Safety directives letter No	Nil
7. Date of inspection	12/03/2026
8. Name of Inspecting Officer	ADO (Rohini) & DO (NW)
9. Name and designation of officers From the building side	Smt. Nisha Lakra (Owner)
10. Year of Construction	2000 (As per CAF)
11. Applicant's letter No.	Online MCD Portal ID No. 2026022602121 dated 26/02/2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			MR
	• Road width	06M	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Restaurant at Ground floor only		
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 Exits of 1.50m each	Provided	MR
3.	Compartmentation	Restaurant at Ground floor only		
	• Fire check door	Required in Kitchen	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors (Ground floor)	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	06nos.	06nos.	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

RS

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450 Lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 Ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA

Fire Control Room

N/14

• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

Note:- The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/EH/2026/WZ/76 dated 23/01/2026 have been complied by the management.

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended for Grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

C.L. Meena
17/3/2026
Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO (R)

A.K. Jaiswal
17/03/2026
Signature of the Inspecting Officer
Name :- A.K Jaiswal
Designation:- DO (NW)

Dy CFO (WZ)

KVP
18/03/26

Pr. Director

My. CFO to Gen.

18/02/26

My. CFO (WZ)

F.T. please.

KVP
20/03/26

ADO (R)

As approved, F.T. letter is put up for your signature please

C.L. Meena
28/3/2026

Dy CFO (WZ)

KVP
28/03/26

F.P. wing

Uploaded
27/03/26