

C/179

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**

No. F.6/DFS/MS/Hospital/2025/SZ/151

Dated: 27/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Super Specialty Hospital Wing of DDU Hospital at C-2B, Janak Puri, New Delhi-110058**, comprised of basement (parking & services), ground floor plus five upper floors was issued FSC by this department vide letter No. F.6/DFS/MS/Hospital/2021/SZ/429 dated 02.09.2021, owned/occupied by Govt. of NCT of Delhi. The Hospital building was re-inspected by the officers concerned of this department on dated 19.03.2025 in the presence of Sh. Harish Yadav, JE (Civil), Sh. Bharat Lal Meena, AE (Elect.) & Dr. Shiva (Hospital), and found that Super Specialty Hospital Wing of DDU Hospital have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class Group-C "**Institutional Building**" Sub. Div. C-1 with effect from 27/03/2025 for a period of **03 years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on 27/03/2025 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Delhi: for information regarding use of basement and to ensure the occupancy as detailed above and deviation, if any.
2. The Authorized Signatory, M/s. Super Specialty Hospital Wing of DDU Hospital at C-2B, Janak Puri, New Delhi-110058.
3. The MS, Nursing Homes, Directorate of Health Services, Govt. of NCT of Delhi, S-1, 3<sup>rd</sup> Floor, School Block, Shakarpur, Delhi-110092.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. All passage shall be kept free from obstructions.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per the building bye laws and all passages & staircases shall be kept free from obstructions.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
11. Road all around the hospital should be kept free from all obstructions.

N/33

## INSPECTION REPORT

1. Name & address of the building : Super Specialty Hospital Wing of DDU Hospital, C-2B, Janak Puri, New Delhi-110058.
2. Building comprised of : Basement (parking/services), ground plus five upper floors.
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Hospital/2021/SZ/429 dated 02.09.2021
6. Fire Safety directives letter No : F.6/ MS/DFS/BP/2002/1313/Hospital dated 13.08.2002
7. Date of inspection : 19.03.2025
8. Name of Inspecting Officer : R.K. Yadav, ADO (JKP)
9. Name and designation of officers From the building side : Sh. Harish Yadav, JE (Civil), Sh. Bharat Lal Meena, AE (Elect.) & Dr. Shiva (Hospital Side)
10. Year of Construction : 2007
11. Applicant's letter No. : 24(8)/AE (E)-III/PWD HMED SW/2024-25/24, dated 18.03.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible (09 mtrs) 05 mtrs 06 mtrs	30 & 24 mtrs 05 mtrs Provided	MR MR MR
<b>2.</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	11 no.'s & 01 ramp 11 no.'s & 03 ramp	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	2.0 M 2.0 M	1.93 m (06 no.'s) & .97 to 1.0 m (05 no.'s) & 2.6 m ramp 1.93 m (06 no.'s) & .97 to 1.0 m (05 no.'s) & 5.0 m (02 no.'s) ramp	MR, old case MR, old case
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	Required	Four	MR
	e. Width of Corridor	N/A	2.9 m	MR
	f. Door Size	N/A	Corridor doors 2.30M & ward doors 1.40 M	MR
<b>3.</b>	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required N/A N/A Required	Provided Sealed N/A N/A Provided	MR MR N/A N/A MR
<b>4.</b>	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	Required Required	Provided Provided	MR MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	12 no.'s at each floor ABC/WCO <sub>2</sub> /CO <sub>2</sub> type ISI marked	Provided Provided Provided	MR MR MR

15

N/34

6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	06 no.	Provided	MR
		30 m	Provided	MR
		05 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	MR
		Required	Near main gate	MR
		Required	Near main gate	MR
		Required	Provided	MR
		Required	In staircase	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm	Provided	MR
		Six	Provided	MR
		Six	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Eight	Eight	MR
		Eight	Eight	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	2850 LPM	Provided	MR
		60 Mtr	Provided	MR
		Two	Provided	MR
		180 LPM (02 no.'s)	Provided	MR
		40 mtr	Provided	MR
		2850 LPM	Provided	MR
		60 Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	200000 ltrs.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		30,000 ltrs	Provided	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			

N/35

6.	<b>Provision of Lifts.</b> <ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	Required	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply			
18.	<b>Refuge Area.</b> <ul style="list-style-type: none"> <li>&gt; Total Area</li> <li>&gt; Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19.	<b>Fire Control Room</b> <ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		Required	LT Panel is provided with automatic Clean agent fire suppression system	MR
20.	Special Fire Protection System for Protection of special Risks, if any:	Required		

The fire protection systems provided in the building were tested, checked and found functional at time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/Hospital/2024/SZ/345 dated 21.06.2025 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/Hospital/2021/SZ/429 dated 02.09.2021, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*R. K. Yadav*  
 21/07/2025  
 Signature of the Inspecting Officer  
 Name: - R. K. Yadav  
 Designation: ADO (JKP)

DO/SW  
*[Signature]*  
 24/3/25  
 CFS/  
 24/3/2025  
 Director  
*[Signature]*

*[Signature]*