



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/Banq./2026/NZ/ 880

Dated: 16/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Surya Prime Banquet and Caterer (A Unit of T AND T Event Management Co.) located at Kh. No. 11/20, Ground Floor, Near Hanuman Mandir, Shastri Park, Amrit Vihar, Village Burari, Delhi-110084.

Sir,

This has reference to online application received through MCD portal vide ID-2026081810537 dated 18/08/2026 on the subject cited above. In this connection, it is to inform you that the above said assembly building was visited by the officer concerned of this department on 03/09/2026 in presence of Sh. G.S. Rawat. Following shortcoming were observed at the time of inspection.

1. Exit through the temporary hall is not permitted.
2. Fire check doors are not provided in kitchen area, between pucca hall and adjacent temporary hall of tin shed.
3. Smoke ventilation system found not provided.
4. First aid hose reels found provided but not functional.
5. Terrace level pump not found in auto mode.
6. Overhead tank of 15,000 Ltrs water storage capacity found provided against the required capacity of 25,000 Ltrs.
7. Exit signages found not provided.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully


15/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service



Copy to: -

1. MCD Portal ID No. 2026081810537.