



No. F.6/DFS/MS/School/2026/CZ/152

Dated: 18/09/2026

FIRE SAFETY CERTIFICATE

Certified that Swami Sivananda Memorial Primary and Swami Sivananda Memorial Secondary School, located at 31, East Avenue Road, East Punjabi Bagh, New Delhi-110026, Building comprised of Ground plus 2 upper floors (Two blocks in same premises {One Primary and One Senior block} are inter connected with each other at each floor), owned/occupied by Swami Sivananda Memorial Primary & Secondary School, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Delhi Fire Service on 25.08.2026 in the presence of Mr. Jaspal Nakoti (Admin) and the premises is fit for occupancy class **"Group-B, Educational, Sub Division B-1"** with effect from 18/09/2026 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/09/2026 at New Delhi by.


18/9/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Swami Sivananda Memorial Primary and Swami Sivananda Memorial Secondary School, located at 31, East Avenue Road, East Punjabi Bagh, New Delhi-110026 (Online Portal ID- 52026080604918 dated 06/08/2026).
2. Director of Education, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction all the time.
2. All the fire safety arrangements provided therein shall be maintained in good working condition all the time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures management shall be responsible.
4. All the staff members must know the correct method of operation of fire-fighting system and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case regularizations of unauthorized construction/ unauthorized use of land if any.
7. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/11

INSPECTION REPORT

1	Name & Address of the Building	Swami Sivananda Memorial Primary and Swami Sivananda Memorial Secondary School, located at 31, East Avenue Road, East Punjabi Bagh, New Delhi-110026		
2	Type of Occupancy	Group- B, Educational, Sub-Division B-1		
3	Building comprised of	Two blocks in same premises (One Primary block and One Senior block) are inter connected with each floor comprised of Ground + 2 Upper Floor		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	D.O.E. Circular no. 3298-3398 dated 01.03.2011		
7	Date of Inspection	25/08/2026		
8	Name of the Inspecting Officers	Vinay Kumar (ADO/Patel Nagar)		
9	Name & Designation of Officers from the building side	Mr. Jaspal (Admin)		
10	Year of construction	NA		
11	Applicant letter No.	Portal ID- 52026080604918 dated 06/08/2026		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Fire Safety Requirement as UBBL-2016	Provided at Site	Remarks
1	Access to Building.			
	• Road width	06 mtrs.	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	• Upper floors	02 nos.	02 nos.	MR
	• Basement floor	NA	NA	NA
	b. Width of Staircase			
	• Upper floors	1.5 mtrs.	1.5 m x 2	MR
	• Basement floor	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	02 nos.	Provided	MR
	e. Width of corridor	1.5 m	Provided	MR
	f. Door size	1.2 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers.			
	• Total numbers	Required	Provided 9 nos.	MR
	• Types	CO2, ABC	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 no.	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

7	Automatic fire detection & alarming system.				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooter's location	NA	NA		NA
8	MOEFA	NA	NA		NA
9	Public Address System	NA	NA		NA
10	Automatic Sprinkler System				
	• Basement	NA	NA		NA
	• Upper floors	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11	Internal Hydrants.				
	• Size of Riser/Down-comer	NA	NA		NA
	• Number of Hydrant per floor	NA	NA		NA
	• Hose box.	NA	NA		NA
12	Yard Hydrants.				
	• Total number of hydrants.	NA	NA		NA
	• Hose box.	NA	NA		NA
13	Pumping arrangements.				
	• Ground Level				
	➤ Discharge of main pump.	NA	NA		NA
	➤ Head of main pump.	NA	NA		NA
	➤ Number of main pumps.	NA	NA		NA
	➤ Jockey Pump output.	NA	NA		NA
	➤ Jockey Pump head.	NA	NA		NA
	➤ Standby Pump output.	NA	NA		NA
	➤ Standby Pump head.	NA	NA		NA
	➤ Auto Starting / Manual Stopping.	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace Level				
	➤ Discharge of pump.	450 LPM	Provided		MR
	➤ Head of pump.	40 m	Provided		MR
	➤ Power supply.	Required	Provided		MR
	➤ Auto starting of pump.	Required	Provided		MR
14	Captive water storage for Fire Fighting.				
	• Underground tank capacity.	NA	NA		NA
	➤ Draw-off connection.	NA	NA		NA
	➤ Fire Service Inlet.	NA	NA		NA
	➤ Access to tank.	NA	NA		NA
	• Overhead tank capacity.	10,000 ltr.	Provided		MR
15	Exit Signage.	Required	Provided		MR
16	Provision of Lifts.				
	• Pressurization of lift shaft.	NA	NA		NA
	• Pressurization of lift lobby.	NA	NA		NA
	• Communication in lift car.	NA	NA		NA
	• Fireman's switch.	NA	NA		NA
	• Lift signage.	NA	NA		NA


11/13

17	Standby Power Supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room.			
	• Detector System Panel.	NA	NA	NA
	• Flow Switch Panel.	NA	NA	NA
	• PA system Panel.	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building floor plan	NA	NA	NA
20	Special Fire Protection System for the Protection of special Risk, if any:	NA	NA	NA


The Fire protection systems provided in the building were tested/checked at random and found functional at the time of inspection. The shortcomings issued earlier vide letter no. F6/DFS/MS/School/WZ/2026/574 dated 25/05/2026 rectified by the management

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, **it is recommended to grant Fire Safety Certificate** under Rule 35 (3) of the Delhi Fire Service Rules, 2010.


Accordingly, DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Vinay Kumar
ADO (Patel Nagar)

DO (CD)

 3/8/26


CFO (CENT)

 8/9/26

Principal Director

CFO to Secy. Navr 8/9


CFO (CENT)


 10/9/26

ABO/PH

Sir, F.T letter is put-up for signature please.

C.F.O (Central)

 11/9/26

 14.9.26

PHS