



C/44

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2025/SZ/172

Dated: 16 / 04 / 2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Tara Palace Guest House situated at Prop. No. 4606, Street No. 13, Ansari Road, Daryaganj, New Delhi-110002**

Sir,

Please refer to online (etl.mcdonline.nic.in) ID. 2025010300117 dated 22/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 03/04/2025 in the presence of Sh. Naveen Singh (Manager) of the guest house and the shortcomings observed are as below.

1. Terrace level pump was not on auto mode.
2. Overhead water storage exclusive for firefighting found used for domestic purpose.
3. 4<sup>th</sup> Floor/Terrace found used for kitchen, despite submitting an affidavit regrading not to use any floor above third floor.

In view of the above, the application for renewal of fire safety certificate is rejected. **It is requested that operation of guest house may be stopped immediately in view of the violation of affidavit dated 02.08.2022 regarding not to use any floor above 3<sup>rd</sup> floor.** The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Authorized Signatory M/s Tara Palace Guest House situated at Prop. No. 4606, Street No. 13, Ansari Road, Daryaganj, New Delhi-110002