

C/76

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**


No. F.6/DFS/MS/Assembly/SZ/2025/ 669

Dated: 29/12/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Terminal-2 Building, IGI Airport, New Delhi - 110037** all comprises of Ground, Mezzanine & 1<sup>st</sup> floor only, owned/occupied by Delhi International Airport Ltd. was earlier issued FSC by this department vide letter No. F.6/DFS/MS/2023/SZ/33 dated 24/01/2023. The premises was re-inspected by the officer concerned of this department on 27/11/2025 in the presence of Anand Kumar Agnihotari (GM/AEP) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Building D-5**" Ground, Mezzanine & 1<sup>st</sup> floor only with effect from 29/12/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.. 29/12/2025.....at New Delhi by.

  
26/12/25  
(A.K. Malik)  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to: -**

1. Sh. Selvaraj Arumugam, Vice President & Head – ARFF, Delhi International Airport Ltd., IGI Airport, New Delhi – 110037.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The trained firefighting staff should be available at the site round the clock.
6. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning authority.
7. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any. Basement shall be used as per BBL concerned.
9. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	Terminal-2 Building, IGI Airport, New Delhi - 110037		
2	Type of Occupancy	D - 5 "Assembly"		
3	Building Comprised of	Ground, Mezzanine & 1 <sup>st</sup> floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2023/SZ/33 Dt. 24/01/2023		
6	Fire Safety Directives Letter No.	Nil		
7	Date of Inspection	27/11/2025		
8	Name of the Inspecting Officers	Kaushal Kishore, ADO (SJ)		
9	Name & Designation of Officers from the building side	Anand Kumar Agnihotari (GM/AEP)		
10	Year of construction	Prior to 1983		
11	Applicant letter No. DIAL/ARFF/01/2025-26/25 dated 17.10.2025 received through Outdoor Diary No..7383 dated 23/10/2025			
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building			
	• Road width	09m	09m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	05 Nos	05 Nos. & 01 ramp	MR
	➤ Basements	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	6 feet 6 inch	2m each + ramp 6m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	Provided	MR
	➤ Pressurization	N/A	N/A	MR
	d) No. of continuous staircase to terrace	N/A	N/A	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	Required	3.0/2.0/1.8/1.5/1.2	MR
3	Compartmentation.			
	➤ Fire check door.	N/A	Provided	N/A
	➤ Sealing of electrical shafts.	Required	Provided	MR
	➤ Fire rating of shaft door.	N/A	1 hrs.	N/A
	➤ Water curtain	N/A	N/A	N/A
	➤ Fire dampers.	N/A	N/A	N/A
4	Smoke Management system			
	➤ Basement	N/A	N/A	N/A
	➤ Upper floors	Required	Automatic smoke extraction system with integrated fire alarm system	MR
5	Fire Extinguishers.			
	➤ Total numbers	Required	100 Nos.	MR
	➤ Types	ABC/CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	➤ ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	➤ Total numbers on each floor.	N/A	19 Nos.	N/A
	➤ Length of hose-reel hose.	N/A	30m	N/A
	➤ Nozzle Diameter	N/A	5mm	N/A


7	Automatic fire detection & alarming system			
	➤ Type of detectors (In Basement)	N/A	N/A	N/A
	➤ Location of Main Panel	N/A	Ground floor	N/A
	➤ Location of Repeater Panel	N/A	Fire Control Room	N/A
	➤ Alternate source of power	N/A	UPS/Batteries/Gen.	N/A
	➤ Hooter's location	N/A	All corridor, Exit gate	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System	N/A	Available at all level in passenger movement area	N/A
10	Automatic Sprinkler System			
	➤ Basement	N/A	N/A	N/A
	➤ Upper floors	N/A	Provided	N/A
	➤ Sprinkler above false ceiling	N/A	Provided	N/A
11	Internal Hydrants.			
	➤ Size of Riser/Down-comer	N/A	150mm	N/A
	➤ Number of Hydrant per floor	N/A	19 Nos.	N/A
	➤ Hose box.	N/A	19 Nos.	N/A
12	Yard Hydrants.			
	➤ Total number of hydrants.	N/A	15 Nos.	N/A
	➤ Hose box.	N/A	15 Nos.	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump	N/A	2850 LPM	N/A
	➤ Head of main pump	N/A	70m each	N/A
	➤ Number of main pumps	N/A	1 + 1 No.-	N/A
	➤ Jockey pump out put	N/A	280 LPM	N/A
	➤ Jockey pump head	N/A	60m each	N/A
	➤ Stand by pump output	N/A	2850 LPM	N/A
	➤ Stand by pump head	N/A	70m	N/A
	➤ Auto starting/Manual stopping	N/A	Provided	N/A
	➤ Pump House Access	N/A	Provided	N/A
	• Terrace Level			
	➤ Discharge of pump.	N/A	N/A	N/A
	➤ Head of pump.	N/A	N/A	N/A
	➤ Power supply.	N/A	N/A	N/A
	➤ Auto starting of pump.	N/A	N/A	N/A
14	Captive water storage for firefighting.			
	• Underground tank capacity.			
	➤ Draw-off connection.	N/A	5,00,000 ltr	N/A
	➤ Fire Service Inlet.	N/A	Provided	N/A
	➤ Access to tank.	N/A	Provided	N/A
	• Overhead tank capacity.			
		N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	➤ Pressurization of lift shaft.	N/A	N/A	N/A
	➤ Pressurization of lift lobby.	N/A	N/A	N/A
	➤ Communication in lift car.	N/A	Provided	N/A
	➤ Fireman's switch.	N/A	Provided	N/A
	➤ Lift signage.	N/A	Provided	N/A
17	Standby Power Supply	Required	Provided UPS/DG Set	MR
18	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19	Fire Control Room.			
	➤ MOEFA System Panel.	N/A	N/A	N/A
	➤ Flow switch panel.	N/A	N/A	N/A
	➤ PA system panel.	N/A	N/A	N/A
	➤ Battery backup.	N/A	N/A	N/A
	➤ Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for Protection of Special Risk, if any.	GAS suppression system (NOVAC-1230. CO <sub>2</sub> Flooding System, Trace Tube & FM 200) in all electric (Panels & Sub Stations).		N/A

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2023/SZ/33 dated 24/01/2023, D-5 "Assembly"- Ground, Mezzanine & 1<sup>st</sup> floor, Terminal-2 Building, IGI Airport, New Delhi - 110037, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


Accordingly, DFA is put up for approval and signature please.

  
Signature of the Inspecting Officer  
Name: Kaushal Kishore  
Designation: ADO (SJ)

DO (SD)  
  
**Ravinder Singh**  
9/11/23

  
**A.K. MALIK**  
Principal Director

By. CFA to Gen.  
  
10/12/23

  
**A.K. MALIK**  
  
