



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/GH/SZ/2026/ 845

Dated: 09/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o. M/s. The Ambient Suite, located at A-56, first floor, kailash Colony, New Delhi-110019.


Sir,

Please refer to your online application no. No. 2026080510319 dated- 05/08/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 24/08/2026 in the presence of Mr. Vimal Arora to see the functioning of fire safety arrangements/equipment's provided in the building. During the inspection, the following shortcomings were observed.

1. One staircase is provided having width of 1.16m against the requirement of 2X1.5m.
2. Fire Check doors are not provided.
3. Width of corridor is 1.15m provided against the requirement of 1.8m.
4. Smoke management system is not provided.
5. Final exits of width 1.2m are provided against the requirement of 1.5m each.
6. First Aid Hose reels & Hydrants are not provided.
7. MOEFA & Co2 type detectors are not provided.
8. Terrace pump capacity of 450 LPM, is not provided.
9. Over Head water storage tank capacity of 20,000ltrs is not provided.
10. Exit Signage are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected.

Yours faithfully,


A.K. Malik

Chief Fire Officer

01/09/26

Copy To: -

1. The Owner/occupier M/s The Ambient Suite, located at A-56, first floor, kailash Colony, New Delhi-110019. (Online application No. 2026080510319 dated- 05/08/2026).