

610

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/EH/NDZ/2026/ 38

Dated: 15/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s The Big Chill Cakery located at Plot No.-5, Ground Floor, Block-II, Block B, Middle Circle, Connaught Place, New Delhi – 110001 comprised of Ground plus 02 Upper floors. The premises was inspected by the officer concerned of this department on 03/01/2026 in the presence of Mr. Ashwini Kumar, Manager and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - Assembly Building (Group D), Restaurant running at Ground floor only, with effect from15/01/2026.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ---15/01/2026---at New Delhi by.


14/1/26

(Dr. S. K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

W

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2025122516098 & 2025102214314 Dt. 25/12/2025.
2. The Manager, M/s The Big Chill Cakery, Plot No.-5, Ground Floor, Block-II, Block B, Middle Circle, Connaught Place, New Delhi – 110001.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Restaurant running at Ground Floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, electric installation, set bac area etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT				
1.	Name & address of the building	M/s The Big Chill Cakery located at Plot No.-5, Ground Floor, Block-II, Block B, Middle Circle, Connaught Place, New Delhi – 110001.		
2.	Type of occupancy	Assembly Building (Restaurant) – Group -D		
3.	Building is Comprised of	Ground plus Two Upper Floors (Restaurant running at Ground Floor only)		
4.	Type of case	Fresh		
5.	Details of previous FSC No.	N/A		
6.	Fire safety directives No.-	N/A		
7.	Date of inspection: -	03.01.2026		
8.	Name of the inspecting officer: -	Sh. Kaushal Kishore, ADO (SJ)		
9.	Name & designation of officer From the building side: -	Sh. Ashwini Kumar, Manager		
10.	Year of construction: -	1950		
11.	Applicant's letter No: -	Online MHA Portal ID. No- 2025122516098 & 2025102214314 Dt. 25/12/2025		
S. No.	Minimum Standards on fire Prevention and fire safety U/R	Requirement/ Fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building	Restaurant running at GF.		
	• Road width	06 mtr.	12 mtr.	MR*
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits	Restaurant running at GF.		
	a. Number of staircases	Restaurant running at GF.		
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase	Restaurant running at GF.		
	• Upper floors	N/A	Provided 1.50 mtr. each	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	02 nos.	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50 mtr.	1.50 mtr.	MR
3.	Compartmentation	Restaurant running at GF.		
	• Fire check door	Required	Provided at Kitchen	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System	Restaurant running at GF.		
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural	MR
5.	Fire Extinguishers			
	• Total numbers	06 nos.	06 nos.	MR
	• Types	ABC/CO ₂ /W.CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System.			

	• Type of detectors	Smoke	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Each Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box per floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	40 mtr.	40 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	Required	Provided	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs	20,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A

M/s The Big Chill Bakery located at Plot No.-5, Ground Floor, Block-II, Block B, Middle Circle, Connaught Place, New Delhi - 110001.

20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A
-----	--	-----	-----	-----

*PNF - Provided but Non-Functional, *MR - Meeting Requirement, *NMR - Not Meeting Requirement


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


Keeping in view of the substantial compliance minimum standards of fire prevention and fire safety measure as required under the rules, if approved, we may issue FSC to said restaurant. The last date of deemed approval is 23/01/2026.

Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer



Name:- Sh. Manish Kumar
Designation :- DO (CD)


Name :- Sh. Kaushal Kishore
Designation : ADO (SJ)

Dy. CFO (NDZ)


9/1/26

Principal Director

Dy. CFO + Secy.

12/01/26


Dy. CFO (NDZ)


13/1/26

ADO (SJ)

14/1/26

FT letter is prepared and put up for signature please.


14/1/26
(KAUSHAL KISHORE)
ADO (SJ)

Dy. CFO (NDZ)


14/1/26

