

d04

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/School/2025/WZ/ 179

Dated: 01/04/2025

To:
The Principal,
The Grammar School,
Plot No. 13, I Block, Phase 1,
Ashok Vihar, Delhi-110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o The Grammar School located at Plot No. 13,
I- Block, Phase-1, Ashok Vihar, Delhi- 110052.

Sir,
This has reference to your letter no. nil dated 06.02.2025 received through outdoor diary no. 12274 dated 10.02.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 22.03.2025 in presence of Sh. Prashan Verma to verify the fire safety arrangements provided therein.

During the course of inspection it was observed that school building is comprised of Small Basement, Ground and Two Upper Floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. First aid hose reels found provided but not functional.
2. Terrace level pump of 450 lpm discharge capacity not found in auto mode.
3. Exit signage's not provided.

Keeping in view of above, the application for issuance of fire safety certificate cannot be considered at this stage & rejected. You are requested to rectify the above-mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours Faithfully

(Atul Garg)
Director

Ph/011-23414000

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, Delhi.