

C-95

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/BNQT./2025/WZ/ 59

Dated 06/11/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s The Grand Horizon Banquets (A Unit of KRK Hospitality) Located at 11-A, Shivaji Marg, Moti Nagar, New Delhi-110015, comprised of 02 Basement, Ground + 02 upper floors only but the said banquet hall is running at Ground + 02 upper floors, owned/occupied by M/s The Grand Horizon Banquets (A Unit of KRK Hospitality), FSC issued vide letter no. F.6/DFS/MS/BNQT/WZ/2022/54 dated 11/10/2022. The premise was inspected by the officer concerned of this department on 26/10/2025 in the presence of Sh. Kapil Gupta (Owner) found that the premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Assembly, Group-D" with effect from 06/11/2025 and valid up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...06/11/2025.....at New Delhi by


(S. K. DUA)

o/c DY. CHIEF FIRE OFFICER
2. DELHI FIRE SERVICE

Copy to:-

1. M/s The Grand Horizon Banquets (A Unit of KRK Hospitality) Located at 11-A, Shivaji Marg, Moti Nagar, New Delhi-110015.

MCD ID No. 2025100513967

Conditions for the validity of Fire Safety Certificate

1. Tin shed shall not be used for banquet and any purpose & Basement shall be used as per BBL, the FSC will be treated as null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The basement shall be used as per the provisions of BBL/NBC Part-IV.
6. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
7. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s The Grand Horizon Banquets (A Unit of KRK Hospitality) Located at 11-A, Shivaji Marg, Moti Nagar, New Delhi-110015.
2. Building comprised : 02 Basement, Ground + 02 upper floors on but the said banquet hall is running at Ground + 02 upper floors.
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/BNQT/WZ/2022/54dt11/10/2022
6. Fire Safety directive letter No : F.6/DFS/MS/BP/2019/2981 dated 21/05/2019
7. Date of Inspection : 29/10/2025
8. Name of the Inspecting officers : Deepak Kumar ADO (TP)
9. Name and designation of Officer from the building side : Sh. Kapil Gupta (Owner)
10. Year of Construction : 2018 (As per Pre. Insp. Report dated 29/08/2022)
11. Applicant's letter No : 2025100513967, Dated- 05/10/2025


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirements per clause 35 (6), Delhi Fire Service Act-2007	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	Provided	MR
	• Basement	02 nos.	1 st Basement-1 Stair & 1 ramp, 2 nd Basement- 02 Stair Provided	MR
	B. Width of Staircases			
	• Upper floor	02m each	Provided	MR
	• Basement	02m & 1.5mts	2m Stair & 4.5 mts ramp Provided	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to terrace	01 nos.	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 m	G. floor- 3x2m, 0.90m, 1 st floor-2x 2m, 1x1.14m 2 nd floor- 2x2m & 1x1.50m provided	MR (Old case)
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	Required in basement	Provided	MR
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	30 a/c per hour	Mec. Provided	MR
	• Upper floor	12 a/c per hour	Mec. Provided	MR
05.	Fire Extinguishers			
	• Total numbers	10 nos.	16 nos.	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	02 nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
07	Automatic Fire Detection and Alarming System:-			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main pane	Required	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter	Required	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 nos.	Provided	MR
	• Hose box	02 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	Required	Provided	MR
	• Hose box	Required	Provided	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	2280 lpm	2280 lpm	MR
	• Head of main pump	70 mtr	70 mtr	MR
	• Number of main pumps	01 nos.	01 nos.	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	70 mtr	70 mtr	MR
	• Standby pump out put	2280 lpm	2280 lpm	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting/manualstopping	Required	Required	MR
	• Pump house access	Required	Required	MR
	➤ Terrace Level			
	• Discharge of pump	450 lpm	2 x 450 lpm	MR
	• Head of the pump	40 mtr	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water storage for fire fighting			
	• Underground tank capacity	2,00,000 Ltr	Provided	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
h e f i	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	
18	Refuge Area.			
p r	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
t e c h n	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/BNQT/WZ/2022/54 dated 11/10/2022 renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.



 30/10/2025
 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : ADO (TP/Shah.)

DO (WB) 
30/10/2025


 Dy. CFA/WZ 
 30/11/25
 Principal Director

Dy. CFA to Secm.




Dy. CFA (WZ)


04/11/25
Dy. CFA (WZ)


ADO (TP)

Sir,
signature pl.

F.T. letter is put up for your kind


 Dy. CFA (WZ) 
 06/11/25
 F.P. wing


 06/11/25