



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/Bnqt./2026//222

Dated: 13/03/2026

To,

Sh. Avneesh Gupta,
M/s The Great Palace Unit of Great Plaza and Catering Pvt. Ltd.,
Ground and Mezzanine floor of PD Area, Package 2
Seelampur Metro Station,
Delhi -110053.

Subject: - Regarding renewal of Fire Safety Certificate for M/s The Great Palace Unit of Great Plaza and Catering Pvt. Ltd., located at Ground and Mezzanine floor of PD Area, Package 2 at Seelampur Metro Station, Delhi -110053.

Sir,

This has a reference to MCD online application ID No. 2026021601656 dated 16/02/2026 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 03/03/2026 in presence of Mr. Sohail Khan, Manager and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/Banquet/NDZ/2026/36 dated 12/01/2026 (copy enclosed) have not been complied yet.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Encl. As above

Yours faithfully,


13/3/26
(Dr. S. K TOMAR)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to :-

The Commissioner, MCD, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-120
C/124
75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Banquet/NDZ/2026/ 36

Dated: 12/01/26

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s The Great Palace (Unit of Great Food Plaza and Catering Pvt. Ltd.) located at Ground and Mezzanine floor of PD area, Package 2, Seelampur Metro Station, Delhi – 110053.

Sir,

With reference to the elt.mcdonline application no. 2025121315662 on the subject cited above, it is informed that the said Banquet Hall was inspected by officer concerned of this department on 01.01.2026 in the presence of Mr. Sohail Khan, Manager and it was observed that the Banquet Hall is running at Ground + Mezzanine floor of the building which is comprised of Ground + Mezzanine floor. During the inspection the following shortcomings were observed:

1. Water based fire protection systems like Fire Pumps, Hose Reels and Internal Hydrants were found non- functional.
2. Electrical cables in the Internal Hydrant shaft must be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


12/1/26
(Dr. S. K. Tomar)

Dy. Chief Fire Officer (NDZ)

9c
09/1/26

Copy to:-

1. The Licensee, M/s The Great Palace (Unit of Great Food Plaza and Catering Pvt. Ltd.) located at Ground and Mezzanine floor of PD area, Package 2, Seelampur Metro Station, Delhi – 110053.