

C-37



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No.F6/DFS/MS/2025/BNQT/ 68

Dated 24/04/2025

To

The Joint Commissioner of Police/ Lic,  
1<sup>st</sup> Floor, Licensing Unit, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s The Meraki Grand located at A-29,  
G.T.K. Road, Industrial Area, Delhi-110033.

Sir,

This has reference to online MCD portal I'd. No. 2025032804871 dated 28.03.2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.04.2025 in the presence of Mr. Tushar Malhotra to check the existing fire safety measures and observed that the building is comprised of basement, ground, mezzanine & 02 upper floors. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. FCD found removed at some places.
2. Ventilation found removed at upper floor & basement.
3. Electrical panel board installed within escape route needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of banquet hall is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director

Ph: 011-23414000

Copy to:-

1. The Meraki Grand located at A-29, G.T.K. Road, Industrial Area, Delhi-110033. 