


No. F.6/DFS/MS/School/2025/SZ/ 1414

Dated: 24/12/2025

FIRE SAFETY CERTIFICATE

Certified that **The Mom's Lap Primary School** located at Khasra No. 16/7, Block-F, Main Shani Bazar Road, Qutub Vihar Phase-I, New Delhi-110071, having two interconnected blocks namely block A and B; comprised of ground + 01 & basement, ground + 01 upper floor respectively, owned/occupied by The Mom's Lap Primary School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by the officer concerned of this department on 11/12/2025 in the presence of Sh. Praveen Gaur (Manager) and that the school premise/building is fit for occupancy class "Educational Group B-I" with effect from 24/12/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/12/2025 at New Delhi by


(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. The Manager, The Mom's Lap Primary School, Khasra No. 16/7, Block-F, Main Shani Bazar Road, Qutub Vihar Phase-I, New Delhi-110071
3. The Commissioner, MCD, 9th Floor, Civic Centre, Minto Road, New Delhi:to verify the authorization of building.

Conditions for the validity of Fire Safety Certificate: -

1. Basement is closed by the school management as undertook vide letter no. 1354 dated 16/12/25. Same shall not be used for school activities, failing which the FSC shall be cancelled.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-1

| INSPECTION REPORT | | | | |
|-------------------|---|--|---|---|
| 1. | Name & address of the building | The Mom's Lap Primary School, Khasra No. 16/7, Block-F, Main Shani Bazar Road, Qutub Vihar Phase-I, New Delhi-110071 | | |
| 2. | Type of Occupancy | Educational (Group B-1) | | |
| 3. | Building Comprised of | Two interconnected blocks namely A & B comprised of G+1 & B+G+1 upper floor. | | |
| 4. | Type of Case | New | | |
| 5. | Details of previous NOC No. | Nil | | |
| 6. | Fire safety directives letter No. | DOE Circular No. 3298 to 3398 Dt. 01/03/2011 | | |
| 7. | Date of inspection | 11/12/2025 | | |
| 8. | Name of the Inspecting Officer | ADO (JKP) | | |
| 9. | Name and designation of Officer from the building side | Sh. Praveen Gaur (Manager) | | |
| 10. | Year of Construction | 2016 | | |
| 11. | Applicant's letter No. | E-mail dated 08/12/2025 | | |
| S. No. | Minimum standards on fire prevention and fire safety U/R 33 | DOE Circular Dt. 01/03/2011 Requirement | Provided at site | Remarks MR/NMR |
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <ul style="list-style-type: none"> Accessible N/A N/A | <ul style="list-style-type: none"> 6.0 mtr Abuts on road N/A | <ul style="list-style-type: none"> MR N/A N/A |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 02 No's N/A | <ul style="list-style-type: none"> 03 No's Closed | <ul style="list-style-type: none"> MR N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 1.5m & if less than 1.5m then addl. of 0.75m N/A | <ul style="list-style-type: none"> 2 of 1.50m each & 1 of 1.20m Closed | <ul style="list-style-type: none"> MR N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <ul style="list-style-type: none"> N/A N/A | <ul style="list-style-type: none"> N/A N/A | <ul style="list-style-type: none"> N/A N/A |
| | d. No of continuous staircase to terrace | N/A | | N/A |
| | e. Width of Corridor | N/A | | N/A |
| | f. Door Size | 1.2 mtr (1.2m) | Provided | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <ul style="list-style-type: none"> N/A N/A N/A N/A N/A | <ul style="list-style-type: none"> N/A N/A N/A N/A N/A | <ul style="list-style-type: none"> N/A N/A N/A N/A N/A |
| 4. | Smoke Managements System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <ul style="list-style-type: none"> N/A Required | <ul style="list-style-type: none"> Closed Natural ventilation | <ul style="list-style-type: none"> N/A MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • ISI marking | <ul style="list-style-type: none"> 02 per floor ABC / CO₂ ISI marked | <ul style="list-style-type: none"> 06 No's ABC & CO₂ Provided | <ul style="list-style-type: none"> MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | <ul style="list-style-type: none"> N/A N/A N/A | <ul style="list-style-type: none"> N/A N/A N/A | <ul style="list-style-type: none"> N/A N/A N/A |

| | | | | |
|-----|--|-----|-----|-----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main pump | N/A | N/A | N/A |
| | ➤ Head of main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive water storage for firefighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw of connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage | | | |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby Power Supply | | | |
| 18. | Refuge Area | | | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|-----|-----|
| 19. | Fire Control Room | | | |
| | ➤ Detector system panel | N/A | N/A | N/A |
| | ➤ Flow Switch Panel | N/A | N/A | N/A |
| | ➤ PA System Panel | N/A | N/A | N/A |
| | ➤ Battery backup | N/A | N/A | N/A |
| | ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of Special Risks, if any; | N/A | N/A | N/A |

Note: Basement in Block B was found closed during the inspection. Further, the school management has undertaken vide letter no. 1354/25 dated 16/12/2025 that basement area is closed. We may issue FSC for ground and first floor only, if agreed please.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under DOE Circular dated 01/03/2011, issuance of fire safety certificate under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

Santosh Kumar
15.12.25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (JKP)

DO (SW)
[Signature]
19/12/25
RAJINDER ATWAL
Dy. C.S. (SZ)

[Signature]
19/12/25
A.K. MALIK

Principal Director

[Signature]
Dy. C.S. (SZ)

[Signature]
Dy. C.S. + Bsm.
19/12/25

[Signature]
22/12/25
A.K. MALIK

[Signature]
22/12

ADO (JKP)
[Signature]