



FIRE SAFETY CERTIFICATE

Certified that **The Mother Marry Public School** at 292 - B, Main Road Mandawali, Delhi-110092, building comprised of Ground plus Four upper floors only, owned / occupied by **The Mother Marry Public School** was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/1006 dated 14/12/2021. The School building was re-inspected by the officer concerned of this department on 28.01.2025 in presence of Mr. Gaurav Varma (Manager) and found that all the said school have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the school is fit for occupancy class Group - B "**Educational Building**" with effect from 04/02/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 04/02/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director (Education), 419, Udyog Sadan, Patparganj Industrial Area, Delhi - 110092.
2. The Principal, The Mother Marry Public School at 292 - B, Main Road Mandawali, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	The Mother Marry Public School at 292-B, Main Road Mandawali, Delhi-110092.			
2	Building is comprised of	Ground + Four Upper Floors			
3	Type of occupancy	Educational Building			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/1006 dated 14/12/2021			
6	Fire safety directives letter no.	DFS Act, 2007 & Rules 2010			
7	Date of inspection	28/01/2024			
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar			
9	Name of the designation of officer from the building side	Mr. Gaurav Varma (Manager)			
10	Year of construction	2001			
11	Applicant's letter no.	Outdoor diary no. 10365 dated 16/12/2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A Road width	6.0 meters.	6.0 meters. ✓	MR	
	B Gate width	N/A	N/A	N/A	
	C Width of internal road	N/A	N/A	N/A	
2	Number, Width, Type and Arrangement of Exits:				
	A Number of staircases				
	a	Upper floor	01 nos.	02 nos. ✓	MR
	b	Basement	N/A	N/A	N/A
	B Width of staircases				
	a	Upper floor	1.5 mtr.	1.5 m, (1.05 m upto 2 nd floor & 1.2 m from second floor to terrace)	MR
	b	Basement	N/A	N/A	N/A
	C Protection of exits				
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	01 no.	02 no. ✓	MR
	E	Width of corridor	1.5 mtrs.	1.5 mtrs. ✓	MR
	F	Door size	1.0 mtr.	1.0 mtr. ✓	MR
3	Compartmentation:				
	A	Fire check door	N/A	N/A	N/A
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A


5. Fire Extinguisher:				
A	Total numbers	10 nos.	10 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR.
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtr.	30 mtr.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	1 no.	1 no.	MR
C	Hose box	1 no.	1 no.	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	900 LPM	900 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

②

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	50,000 ltr. MR
	B	Draw-off connection	N/A	Provided MR
	C	Fire service inlet	N/A	Provided MR
	D	Access to tank	N/A	Provided MR
	E	Overhead tank capacity	25,000 liters.	25,000 liters. MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A N/A
	B	Pressurization of lift lobby	N/A	N/A N/A
	C	Communication in lift car	N/A	N/A N/A
	D	Firemen's grounding switch	N/A	N/A N/A
	E	Lift signage	N/A	N/A N/A
17	Standby Power Supply:		N/A	N/A N/A
18	Refuge Area:			
	A	Total area	N/A	N/A N/A
	B	Location	N/A	N/A N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A N/A
	B	Flow switch panel	N/A	N/A N/A
	C	PA system panel	N/A	N/A N/A
	D	Battery backup	N/A	N/A N/A
	E	Building floor plans	N/A	N/A N/A
20	Special Fire Protection systems for protection of special Risks, if any:			N/A


The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcoming issued vide letter No. F6/DFS/MS/School/NDZ/2025/33 dated 15/01/2025 has been rectified.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2021/1006 dated 14/12/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


29/1/2025

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (Laxmi Nagar)


D.O/EAST


30/01/2025

Dy. C.F.O. (NDZ)


30/01/25

C.F.O.


31/01/2025
Director



P.T.O