



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Bnqt/2025/WZ/ 175

Dated: 21/10/2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, JLN Marg,
Minto Road, New Delhi-110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o **"The Oreanns Banquet"** (A unit of MS Ghar O Bar Hospitality Pvt. Ltd) located at 69/6A Najafgarh Road, Industrial Area, Moti Nagar, Delhi-110015

Sir,

Please refer to the online portal application No. **2025092313670** dated 23/09/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 08/10/2025 in presence of Sh. Dupinder Singh (Manager) to verify the availability and operability of fire protection measures. During course of inspection, the shortcomings observed are as below.

1. First-aid hose-reel provided found non-functional.
2. Terrace level fire pumps provided found non-functional.
3. Exit signage's found removed at some locations.
4. Approval of MCD for running of banquet at basement floor & kitchen at 2nd floor may be submitted.

In view of the above, application for issuance of fire safety certificate cannot be considered & rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(S.K. DUA)

Dy. Chief Fire Officer(WZ)
Delhi Fire Service

Copy to: -

1. Sh. Manpreet Singh Garewal, "The Oreanns Banquet" (A unit of MS Ghar O Bar Hospitality Pvt. Ltd) located at 69/6A Najafgarh Road, Industrial Area, Moti Nagar, Delhi-110015