



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/GH/SZ/2026/11

Dated: 06/01/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s The Pamposh (Edwin Hospitality Service) located at A-5 Pamposh Enclave, G. K. 1, Delhi-110048, comprised of basement + ground + 03 upper floors, and guest house is running at ground + 03 upper floors, ground floor-6 rooms, 1<sup>st</sup> to 3<sup>rd</sup> floors 9 guest rooms each floors, total-33 guest rooms only has already been issued FSC by this department vide letter No. F.6/DFS/MS/GH/2022/SZ/551 dated 20.12.2022. The premises was re-inspected by the officer concerned of this department on 24.12.2025 in the presence of Mr. Surender Rawat (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "Residential Group-A" (Lodging or Rooming House) with effect from 06/01/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/01/2026 at New Delhi by

  
6/1/26  
(A. K. MALIK)  
Dy. Chief Fire Officer

**Delhi Fire Service**

Copy to: -

1. The Commissioner, MCD, Civic centre, New Delhi : to kindly ensure the occupancy as detailed above and deviation in construction if any : Online MCD Portal ID-2025112615165 dated 03.12.2025
2. Mr. Surender Rawat (Manager)M/s The Pamposh (Edwin Hospitality Service) located at A-5 Pamposh Enclave, G. K. 1, Delhi-110048

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

M/29

**INSPECTION REPORT**

1. Name & address of the building		M/s The Pamposh (Edwin Hospitality Service) located at A-5 Pamposh Enclave, G. K. 1, Delhi-110048.		
2. Type of Occupancy		Residential Group 'A'		
3. Comprised of building		Basement + Ground + 03 upper floors		
4. Type of Case		Renewal (Guest house is running at ground + 03 upper floors) Gr. floor-06 rooms 1 <sup>st</sup> floor to 3 <sup>rd</sup> floor 9 guest rooms each floors Total-33 guest rooms		
5. Details of Previous NOC		F.6/DFS/MS/GH/2022/SZ/551 dated 20.12.2022.		
6. Fire Safety directives letter No		-NA-		
7. Date of inspection		24.12.2025		
8. Name of Inspecting Officer		Sh. Ajay Kumar Sharma ADO (Wazirpur/MN)		
9. Name and designation of officers From the building side		Mr. Surender Rawat (Manager)		
10. Year of Construction		2008 on MCD Portal		
11. Applicant's letter No.		Online application No.2025112615165 dated 03.12.2025.		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements Rule 35 (6)	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12m	Provided	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01nos.	Provided	MR
	• Basements	02nos.	Provided	MR
	<b>b. Width of staircases</b>			
	• Upper Floor	1.25m	1.25m	MR
	• Basements	1.25m & 0.90m	1.25m & 1.0m	MR
	<b>c. Protection of exits</b>	As per clause 7.31 of IBBL 2016		
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	01nos.	Provided	MR
	<b>e. Width of Corridor</b>	-NA-	-NA-	-NA-
	<b>f. Door Size</b>	1m	1.25m final exit	MR
3.	<b>Compartmentation</b>			
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	Required	Provided	MR
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>	As per clause 7.31 of IBBL 2016		
	a) Basements	30 a/c per hour	Exhaust fan	MR
	b) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	<b>Fire Extinguishers</b>			
	a) Total numbers	16nos.	Provided	MR
	b) Types	ABC/CO2	ABC/CO2	MR
	c) IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			

✍

-N/30

d) Fireman  
e) Lift Signage  
Standby power sup  
18. Refuge Area  
a)

	a) Total numbers on each floor	01nos.	Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			As per clause 7.31 of IBBL 2016
	a) Type of detectors	Co/Mo/type	Provided	MR
	b) Location of Main Panel	Required	Provided	MR
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	Required	Provided	MR
	e) Hooters' Location	Required	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	a) Basement	Required	Provided	MR
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants</b>			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants</b>			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	2 x 450 & 180lpm	2 x 450 & 180lpm	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	b) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	c) Communication In lift Car	Required	Provided	MR

Qm

11/31-

MR  
MR  
MR

d) Fireman's Grounding Switch	Required	Provided	MR
e) Lift Signage	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area.	-NA-	-NA-	-NA-
a) Total Area	-NA-	-NA-	-NA-
b) Location	-NA-	-NA-	-NA-
19. Fire Control Room	-NA-	-NA-	-NA-
a) Detector System Panel	-NA-	-NA-	-NA-
b) Flow Switch Panel	-NA-	-NA-	-NA-
c) PA System Panel	-NA-	-NA-	-NA-
d) Battery backup	-NA-	-NA-	-NA-
e) Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/GH/2022/SZ/551 dated 20.12.2022 is recommended for renewal of FSC under rule 37 of the Delhi Fire Service rules 2010.

Last date 27/12/25

*[Signature]*  
29/12/25

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Wazirpur/MN)

DO (SD)

*[Signature]*  
29/12/25

*[Signature]* Please put up a fair DFA.

*[Signature]*  
29/12/25

*[Signature]* fair DFA put up for kind review  
A.K. MALIK  
29/12/25  
Ravinder Singh

*[Signature]*  
29/12/25

*[Signature]*  
30/12/25  
A.K. MALIK

Principal Director

*[Signature]*  
02/01/25