

C/50



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F.6/DFS/MS/GH/2025/SZ/186

Dated: 21/04/2025

To

The Addl. Commissioner of Police (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi 110049

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Tourist International at
8197/6, A.K. Road, Pahar Ganj Delhi 110055

Sir,

This has reference with **MCD Portal 2025031703738 dated 22/03/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 16/04/2025 in the presence of Md. Kaif (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The Smoke Management system not provided as per clause 7.31 of UBBL 2016.
2. Overhead tank capacity 2000 ltrs provided against the required capacity of 2,500 ltrs.
3. Exit signage found removed at some places.
4. The occupancy above 3rd floor is not allowed as per the clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Atul Garg
21/4/25