

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2026/ 28

Dated: 23/02/2026

FIRE SAFETY CERTIFICATE

Certified that the **Toy Bank cum Cultural Centre**, located at **Plot No. 28, 29, Deen Dayal Upadhyay Marg, New Delhi – 110001** building comprised of 02 Basement, Ground and 03 Upper Floors. The said premises was inspected by the officers concerned of this department on **19/02/26** in the presence of **Sh. Rakesh Kumar Gupta, J.E.(MCD)** and **Sh. Tarun Khurana, Building's Side** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Assembly building: Group – D** with effect from **23/02/2026** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued 23/02/2026 at New Delhi by.



(Dr. S. K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Proprietor, Toy Bank cum Cultural Centre, located at Plot No. 28, 29, Deen Dayal Upadhyay Marg, New Delhi – 110001.
2. The Commissioner, Municipal Corporation of Delhi, Minto Road, Civic Centre, New Delhi – 110001.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	Toy Bank cum Cultural Centre, Plot No. 28, 29, Deen Dayal Upadhyay Marg, New Delhi - 110001.		
2.	Type of occupancy	Assembly Building - Group -D 02 Basement, Ground and 03 Upper Floors		
3.	Type of case	Fresh		
4.	Details of previous FSC No.	N/A		
5.	Fire safety directives Nos.-	F6/DFS/MS/BP/2024/199 dated 24/06/2024 & F6/DFS/MS/BP/2019/457 dated 24/12/2019		
6.	Date of inspection: -	19/02/2026		
7.	Name of the inspecting officer: -	Sh. Manish Kumar, DO(CD) Sh. Bhupender Prakash, ADO(CC)		
8.	Name & designation of officer From the building side: -	Sh. Rakesh Kumar Gupta, J.E.(MCD) Sh. Tarun Khurana, Building's Side		
9.	Year of construction: -	2026		
10.	Applicant's letter No: -	Online MCD application ID 10121527 dated 09.02.2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	6.00 mtr.	15.00 mtr.	MR*
	• Gate width	6.00 mtr.	6.00 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	02 nos.	MR
	b. Width of staircase			
	• Upper floors	2 X 2.00 mtr.	2 X 2.00 mtr.	MR
	• Basements	2 X 2.00 mtr.	2 X 2.00 mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02 nos.	02 nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2.00 mtr.	2.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	Required	Provided	MR
	• Water curtain	Required	Provided for Car Lift	MR
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Provided Mechanical	MR
	• Upper floors	Required	Provided Natural	MR
5.	Fire Extinguishers			
	• Total numbers	24 nos.	30 nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A

	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	At each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box per floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	03 nos.	03 nos.	MR
	• Hose box	03 nos.	03 nos.	MR
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	• Head of main pump	40 mtr.	40 mtr.	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	40 mtr.	40 mtr.	MR
	• Stand by pump output	2280 LPM	2280 LPM	MR
	• Stand by pump head	40 mtr.	40 mtr.	MR
	• Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of pump	40 mtr.	40 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltrs	20,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	Required	Provided	MR
	• Pressurization of lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Fireman's switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO ₂ type Fire Extinguisher Provided			MR

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement

M/10

Ref: N/6 and N/7

Submitted that the premises in question has already been inspected on the scheduled dated i.e. 19/02/2026 and accordingly, a note was placed at N/6 for review of guidelines issued by FPW vide letter No. F6/DFS/MS/BP/2024/199 dated 24/06/2024. After examination by FPW the file has been returned with remark to follow the provisions of Rule 35 (3) of Delhi Fire Service Rules-2010.

The requirement of Pump capacity and numbers of pumps for assembly building having height above 10 mtrs. and not exceeding 15 mtrs., as mentioned in guidelines issued by FPW and as prescribed in Table - 7 of NBC 2016 Part - IV are as under:

	(A)	(B)
Sr. No.	Requirement as per Guidelines issued by FPW vide letter No. F6/DFS/MS/BP/2024/199 dated 24/06/2024	Requirement as per Table -7 of Part IV NBC-2016
1.	A fire pump house having two nos. of electrically driven pumps of 2280 LPM capacity (one for hydrant and other for sprinkler system), one standby diesel driven pump of 2280 LPM, two Jockey pump of 180 LPM capacity and one terrace pump of 900 LPM capacity.	One Electric and one diesel pump (stand by) of capacity 2280 LPM, one electric pump of capacity 180 LPM and two nos. terrace pump of 450 LPM capacity each. (This was recommended by FPW in the Guidelines issued vide F6/DFS/MS/BP/2019/457 dated 24/12/2019)

In view of above, if approved Fire Safety Certificate may be recommended with the provisions of Fire Safety requirements including fire pumps as above in column (B) (as prescribed in table-7).

Accordingly, DFA is put up for your kind perusal, approval and signature please.


Manish Kumar
DO (CD)


Bhupender Prakash
ADO (CC)

Dy. CFO (NDZ)


23/2/26

Principal Director

My. CFO to 



23/02/26

My. CFO (NDZ)


23/2/26

DO/CO

So. F.T. letter is put-up for signature please


23/2/26

Dy. CFO (NDZ)


23/2/24

ms