



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No.F.6/DFS/MS/EH/2026/NDZ/ 855

Dated: 09/09/2026

To,

Sh. Bijender Pal Tiwari,  
M/s Travel Inn  
A-138, Block-A Ghazipur, Mayur Vihar Ph-III,  
Delhi-110096.

**Subject: - Regarding issuance of Fire Safety Certificate in r/o M/s Travel Inn located at A-138 Block-A, Ghazipur, Mayur Vihar Ph-III, Delhi-110096.**

Sir,

This has a reference to MCD online application ID No. **2026080710363** dated 13/08/2026 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned restaurant from fire safety point of view on dated 25/08/2026 in presence of Mr. Bijender Pal Tiwari and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/GH/NDZ/2026/310 dated 08/07/2026 (copy enclosed) have not been complied yet.

**In view of above, the application for issuance of Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Encl. As above

(Dr. S. K. TOMAR)

**CHIEF FIRE OFFICER  
DELHI FIRE SERVICE**

Copy to: -

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F.6/DFS/MS/GH/NDZ/2026/ 310

Dated: 08/07/2026

To,

Sh. Bijender Pal Tiwari,  
M/s Travel Inn  
A-138 Block-A Ghazipur, Mayur Vihar Ph-III,  
Delhi-110096.

**Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Travel Inn located at A-138 Block-A, Ghazipur, Mayur Vihar Ph-III, Delhi-110096.**

Sir,

This has a reference to MCD online application ID No. 2026061008617 dated 10/06/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 29/06/2026 in presence of Sh. Bijender Pal Tiwari. The building is comprised of ground plus three upper floors but guest house is running first floor, second floor and third floor only (Ground floor shop). The following shortcomings were observed during the time of inspection.

1. One staircase of 01 meter width is provided against the requirement of two staircases 1.50 meter width.
2. Alternate staircase is not continuous to terrace.
3. Width of corridor is 1.20 meter against the requirement of 1.50 meter width.
4. Fire extinguishers are not provided.
5. First aid hose reel not provided.
6. Carbon mono oxide detector not provided.
7. MOEFA not provided.
8. Terrace pump capacity of 450 lpm with head 40 meter not provided.
9. Overhead Tank capacity of 10,000 liters not provided.
10. Exit signages not provided.

In view of above, **the application for issuance Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Dr. S. K. TOMAR)  
CHIEF FIRE OFFICER  
DELHI FIRE OFFICER

Copy to:-

1. The Commissioner, MCD, Dr. S.P. M. Civic Centre, Minto Road, New Delhi-110002  
MCD ID No. 2026061008617