

157

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/Metro/2025/SZ/ 391

Dated: 30/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Uttam Nagar East Metro Station**, DMRC, New Delhi-110059, comprised of Ground Level, Concourse level & Platform Level, owned/occupied by Delhi Metro Rail Corporation Ltd. was issued FSC by this department vide letter no. /DFS/MS/Metro/2022/SZ/347 dated 03.08.2022. The building was re-inspected by the officer concerned of this department on dated 07.07.2025 in the presence of Sh. Bhriгу Fukan (AM/Fire) and found that the said Metro Station building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class (**Group D "Assembly Building")** w.e.f. 30/07/2025 the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 30/07/2025 at New Delhi.


30/07/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

- 1 The DGM (Operation), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi- 01.


Conditions for validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws/NFPA.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Uttam Nagar East Metro Station, DMRC, New Delhi-110059.
2. Building comprised of : Ground level, Concourse level & Platform level
3. Type of Occupancy : Assembly (Metro Station)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/Metro/2022/SZ/347 dated 03.08.2022
6. Fire Safety directives letter No : F.6/MS/DFS/BP/2004/3132 dated 27.12.2004
7. Date of inspection : 07.07.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Bhriгу Fukan (AM/Fire)
10. Year of Construction : Before 2006
11. Applicant's letter No. : DMRC/O&M/Fire/NOC/L-3/2025/07/03 dated 02.06.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required 05 m N/A	12 m Provided Provided N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 no.'s	Provided	M/R
	• Basement	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	2.0 m	2.0 m (04 no.'s) GF to platform level	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire/smoke check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	2.0 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required 01 Hrs.	Provided	M/R
	• Sealing of electrical shafts	Required	Sealed	M/R
	• Fire Rating of shaft door	02 Hrs	Provided	M/R
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floor	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	25 No.'s ABC/CO ₂ type ISI marked	Provided	M/R
	• Types		Provided	M/R
	• IS marking		Provided	M/R
6.	First-Aid Hose Reels			
	• Total numbers on each floor	06 no.'s at PF level. & 02 no.'s at GF & CC level 45 M 6.5 mm	06 no.'s at PF level. & 02 no.'s at GF & CC level	M/R
	• Length of hose reel hose		Provided	M/R
	• Nozzle diameter		Provided	M/R

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors smoke/heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required Required N/A Required Required	Provided Gr. Floor N/A Provided At exits	MR MR N/A MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required Required Required	150/100 mm 04 no.'s at PF level. & 02 no.'s at GF & CC level 04 no.'s at PF level. & 02 no.'s at GF & CC level	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	M/R M/R
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Terrace Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Discharge of pump  Discharge of pump Head of the pump Power Supply Auto Starting of pump 	(Pump has been shifted on terrace)		
		1800 LPM	Provided	M/R
		60 m	Provided	M/R
		01 no	Provided	M/R
		180 LPM	Provided	M/R
		60 m	Provided	M/R
		1800 LPM	Provided	M/R
		60 m	Provided	M/R
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 50,000 ltrs.	N/A N/A N/A N/A 50,000 ltrs.	N/A N/A N/A N/A M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A N/A N/A Required Required	N/A N/A N/A Provided Provided	N/A N/A N/A M/R M/R

N/14

17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Automatic CO ₂ flooding system in LT panel & Manual CO ₂ flooding system in HT panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/Metro/2022/SZ/347 dated 03.08.2022, renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

R. K. Yadav
10/7/2025

Signature of the Inspecting Officer
Name: - R. K. Yadav
Designation: -ADO (JKP)

DO (S/W)

R. K. Yadav
11/7/25

CFO
11/7/2025

Director
11/7/25

HT letter is put up for sign please

R. K. Yadav
24/7/2025

CFO
24/7/2025

Principal Director

CFO *Prin* *Director*

CFO
24/7/2025

AD