



c/67
75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 145

Dated: 01/04/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

**Sub: Inspection report in r/o M/s Ved Deluxe Guest House located at Prop. No. 3798 to 3800,
Gali Ram Nath Patwa, Pahar Ganj, New Delhi-110055**

Sir,

Please refer to online application No. 2025031303456 dated 13/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 24/03/2025 in the presence of Sh. Narender Gupta (Manager) of the guest house. During course of inspection, the shortcomings observed are as below.

1. Some of the portable fire extinguishers found non-functional.
2. Terrace level fire pump was not on auto mode.
3. Overhead water storage exclusively for firefighting, used for domestic purposes.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Authorized Signatory M/s Ved Deluxe Guest House located at Prop. No. 3798 to 3800, Gali Ram Nath Patwa, Pahar Ganj, New Delhi-110055