

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

NO.F.6/DFS/MS/FH/2026/ 65

Dated 06/03/2026

To,

The Commissioner,  
Municipal Corporation of Delhi,  
Dr. SPM Civic Center, Minto Road,  
New Delhi-110002.

Sub: - Reply of application regarding FSC/NOC in r/o **M/s Veda Farm and Banquets (A Unit of USHA Engg. Agencies LLP), BGF – 54, main road Bijwasan, Delhi – 110061.**

Sir,

This has a reference to online ID- 2026020401235 dated 05/02/2026 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 17/02/2026 in the presence of Sh. Satender. During course of inspection, the shortcomings observed are as below: -

1. Hose reel provided but found non- functional
2. MOEFA is provided but found non-functional.
3. Internal Hydrants provided but found non- functional.
4. Yard Hydrants provided but found non- functional.
5. Terrace pump is provided but found non-functional.
6. Auto starting of terrace pump found non-functional.

In view of the above, application for fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of owner/occupier of the establishment. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(A. K. Malik)  
Dy. Chief Fire Officer

Copy to: -

1. Sh. Satender, M/s Veda Farm and Banquets (A Unit of USHA Engg. Agencies LLP), BGF – 54, main road Bijwasan, Delhi – 110061.