



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/810

Dated: - 27/08/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Vijay Inn Guest House, 876, Gali Chandi Wali, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026071809910 dated 24/07/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 05/08/2026 in the presence of Mr. Raiesh Ajam, Manager and following shortcomings were observed: -

1. Hose reel found damaged in the building.
2. Automatic operation of Fire Pump found removed.
3. Exit signages found removed in the building.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


27/8/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BP

Copy to: -

1. The Manager, M/s Vijay Inn Guest House, 876, Gali Chandi Wali, Paharganj, New Delhi - 110055.