

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2024/SZ/ 629
To

Dated 20/11/2024

M/s VIPPS India (Delhi)
VIPPS Centre-2, Local Shopping Centre,
Block-EFGH, Masjid Moth, Greater Kailash, Part-II,
New Delhi 110048

Sub: - Regarding issuance of fire safety certificate in r/o M/s VIPPS Centre-2, Local Shopping Centre, Block-EFGH, Masjid Moth, Greater Kailash, Part-II, New Delhi 110048

Sir,

This has reference to your letter no VIPPS/DFC/2024/2025 dated 14-10-2024 received through outdoor diary no 7813 dated 14-10-2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.11.2024 in the presence of Mr. Jatin Kumar to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 Fire check door found removed at some places.
- 2 Automatic sprinkler system not working in the basement.
- 3 Fire fighting pumps not on auto mode
- 4 Exit sign not provided in strategic location.

The management of building has made **additional construction at terrace level**. Hence, there is a material change in the building Vis a Vis earlier approval of this department.

The management is hereby advised, either you may restore the earlier composition of building profile or otherwise submit application for sanction of building plans on common application form (CAF) with present floor wise occupancy, on the scales as mentioned in UBBL 2016, for further consideration in the matter.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(AFUL GARG)
DIRECTOR

DELHI FIRE SERVICE