



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/CGHS/2025/SZ/ 464

Dated: 18/09/2025

To

The President / Secretary,
Vrindavan CGHS Limited,
Plot No. 01, Sector-06,
Dwarka, New Delhi-110075

Sub: Renewal of Fire Safety Certificate in r/o Vrindavan CGHS Ltd located at Plot No. 01, Sector-06, Dwarka, New Delhi.

Sir,

This has reference to your letter No. Nil dated 08/08/2025 received in this department vide outdoor diary No. 5248 dated 25/08/2025, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 04/09/2025 in the presence of Sh. P.K. Gupta (Ex. Member) from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. First aid hose-reel system found provided but non-functional.
2. Internal hydrant found non-functional & some hose-boxes empty.
3. Terrace level fire pumps found provided but non-functional.
4. Lift signage's found removed at some locations.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are advised to rectify and submit compliance of above shortcomings for further action in the matter, till than the occupancy of the residential buildings shall be at the risk & liability of the management committee.

Yours faithfully,

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director (L&I), Building Section, Delhi Development Authority, Vikas Sadan, INA, New Delhi-110023