



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2025/School/ 1270

Dated: 29/10/2025

FIRE SAFETY CERTIFICATE

Certified that the Yuva Shakti Model School located at Rama Vihar, Delhi-110081 comprised of Ground & 03 upper floors, But school is running at ground & 02 upper floors only and 3rd floor pota cabin not in use as per given school management undertaking on dated 14/10/2025 owned/ occupied by Yuva Shakti Model School was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/2022/School/WZ/872 Dated: 10/08/2022 the premises was re-inspected by the officer concerned of this department on 06/10/2025 in presence of Mr. Praveen Kumar (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational (School) for ground & 02 upper floors only" with effect from ... 29/10/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ... 29/10/2025 ... at New Delhi by.


(S.K. Dua) 28/10/25

Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi - 110085.
2. The Principal, Yuva Shakti Model School located at Rama Vihar, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. This fire safety certificate is valid for ground & second floor only. And school management has constructed pota cabin at 3rd floor but not in use for school purpose as per given school management undertaking on dated 14/10/2025. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building: : Yuva Shakti Model School at Rama Vihar, Delhi-110081.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & 03 upper floors, But school is running at ground & 02 upper floors only and 3rd floor pota cabin not in use for school purpose as per given school management undertaking on dated 14/10/2025
5. Details of previous NOC : F6/DFS/MS/2022/School/WZ/872 Dated: 10/08/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 06/10/2025
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers from the building side : Mr. Praveen Kumar (Principal)
10. Year of Construction : 2007
11. Applicant's letter No. : Letter No.YMS/RV/DFS/2025-26//02/37 Dated: 28/08/20252

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	NA	NA	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old Case	03 nos. of 0.95 to 1.08m, 1.15m & 1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	01m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA

5	Fire Extinguishers.			
	• Total numbers	10nos	25nos	MR
	• Types	ABC/CO2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	4"	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	220 LPM	Provided	MR
	➤ Jockey pump head	40Mtr	Provided	MR
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	R	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	Required	Provided	MR

M/22

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note:- The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/School/WZ/2025/709 dated 09/09/2025 have been complied by the management.

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended for renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2022/School/WZ/872 Dated: 10/08/2022.

DO/NW
Approved
16/11/2025

C.L. Meena
 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO (Rohini)

Dy. CFO (WZ)
Principal Director

Dy. CFO (WZ)
22/10/25
F.T. pl.
23/10

ADO (Rohini)